

Water Quality Testing Results							
	Tolan Well			Hannegan Brook Well			
Substance	Date Collected	MCL	Results	Date Collected	MCL	Results	Possible Source
ARSENIC	7/24/2008	0.01	ND	8/3/2015	0.01	ND	Naturally occurring contaminant
HALOACETIC ACID	8/11/2014	1.0	ND				Byproduct of drinking water disinfection
INORGANICS	7/19/2011		ND or below MCL	8/12/2016		ND	Salts and Metals
IRON	12/5/2015	0.03	ND	12/5/2015	0.03	ND	
NITRATE	8/12/2016	10.0	ND	8/12/2016	10 mg/L	0.1	Runoff from fertilizer use; leaching from septic tanks; natural deposits
NITRITE	8/12/2016	1 mg/L	ND	8/12/2016	1 mg/L	ND	
PERCHLORATE	8/7/2008	2.0	ND	4/4/2016	2.0 ug/L	ND	Blasting agents, Military munitions and Fireworks
RADIONUCLIDES	8/3/2015	5.06 pCi/L	Below MCL	8/3/2015	Below MCL	ND	Erosion of natural deposits
SODIUM	7/27/2007	20.0 Mg/L	9.62	8/12/2016	20.0mg/L	9.1	Salts
SYNTHETIC ORGANIC COMPOUNDS	1/17/2012		ND	2/1/2016		ND	Pesticides and Herbicides
TRIHALOMETHANES	8/11/2008		ND				Byproduct of drinking water disinfection
VOLATILE ORGANIC COMPOUNDS	10/27/2014		ND	8/18/2016	ug/L	ND	Gasoline and Solvents

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water.

Not Detected (ND)