

WATER ANALYSIS REPORT

Secondary Contaminants

PUBLIC WATER SUPPLY INFORMATION

TURNERS FALLS WATER DEPARTMENT PWS 1192000

LOCATION ID 10050/Well 02G Tolan Well
10053/Well 03G Hannegan Brook Well

LABORATORY ANALYTICAL INFORMATION

Con-test Analytical Laboratory Lab Cert # MA-100

Sample Dates 5/8/2017

Date Analyzed 5/12/2017

Analyte	Results mg/L	Results mg/L	MCL
	Tolan Well #2	Hannegan Brook	Limit mg/L
Alkalinity-Total (CaCO3)	69	28	None
Aluminum (Al)	ND	ND	0.2
Calcium (Ca)	27	4.4	None
Chloride (Cl)	27	18	250
Color	ND	5	15
Copper (Cu)	ND	0.022	1.3
Hardness (CaCO3)	86	18	180
Iron (Fe)	ND	ND	0.3
Magnesium (Mg)	5.6	0.9	None
Manganese (Mn)	ND	0.0034	0.05
Odor	ND	ND	None
pH	7.6	7.4	6.5 - 8.5
Potassium (K)	2.0	14	None
Silver (Ag)	ND	ND	0.10
Sulfate (SO4)	19	8	250
TDS (total dissolved solids)	150	64	None
Turbidity	ND	ND	None
Zinc (Zn)	ND	ND	5

ND = None Detected

MCL = Maximum Contaminant Level