

<b>Water Quality Testing Results</b>							
	<b>Tolan Well</b>			<b>Hannegan Brook Well</b>			
Substance	Date Collected	MCL	Results	Date Collected	MCL	Results	Possible Source
ARSENIC	7/24/2008	0.01	ND	8/3/2015	0.01	ND	Naturally occurring contaminant
HALOACETIC ACID	8/7/2017	1.0	ND				Byproduct of drinking water disinfection
INORGANICS	7/19/2011		ND or below MCL	8/12/2016		ND	Salts and Metals
IRON	8/1/2017	0.03	ND	8/1/2017	0.03	ND	
MANGANESE	8/1/2017	0.05	ND	8/1/2017	0.05	0.0041	
NITRATE	7/31/2017	10.0	ND	7/31/2017	10 mg/L	0.11	Runoff from fertilizer use; leaching from septic tanks; natural deposits
NITRITE	7/27/2017	1 mg/L	ND	7/27/2017	1 mg/L	ND	
PERCHLORATE	7/30/2017	2.0	< 0.05	7/30/2017	2.0 ug/L	< 0.05	Blasting agents, Military munitions and Fireworks
RADIONUCLIDES	8/3/2015	5.06 pCi/L	Below MCL	8/3/2015	Below MCL	ND	Erosion of natural deposits
SODIUM	8/1/2017	20.0 Mg/L	11	8/1/2017	20.0mg/L	9.5	Salts
SYNTHETIC ORGANIC COMPOUNDS	1/17/2012		ND	2/1/2016		ND	Pesticides and Herbicides
TRIHALOMETHANES	7/28/2017		ND				Byproduct of drinking water disinfection
VOLATILE ORGANIC COMPOUNDS	10/27/2014		ND	8/18/2016	ug/L	ND	Gasoline and Solvents

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water.

Not Detected (ND)

